

## **DECLARATION OF PERFORMANCE**

1. Unique identification code of the product-type:**RWX34S**
2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):**Batch Number: See on product ID label.**
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer: **Smoke Alarms installed in buildings**
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5): **RISCO Ltd.,**

**14 Hachoma Street ,75655 Rishon LeZion, Israel**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2): **N/A**
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V: **System 1**
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

The Notified Product Certification Body, 1134  
(ANPI Certification )

**performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance, assessment and approval of factory production control under system 1 and and issued the EC certificate of conformity:**

**1134-CPR-126**

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:**Not applicable. See item 7**
9. Declared performance: **All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the EN 14604:2005/AC:2008 mentioned in the table below:**

Essential characteristics (see Note 1)	Performance (see Note 2)	Harmonised technical specification (see Note 3)
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	passed	4.12, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18
Operational reliability	passed	4.1, 4.2, 4.5, 4.6, 4.7, 4.9, 4.10, 4.13, 4.14, 4.15, 4.16, 4.17, 5.11, 5.16, 5.22, 5.24
Tolerance to supply voltage	passed	5.21
Durability of operational reliability and response delay, temperature resistance	passed	5.7, 5.8
Durability of operational reliability, vibration resistance	passed	5.12, 5.13
Durability of operational reliability, humidity resistance	passed	5.9
Durability of operational reliability, corrosion resistance	passed	5.10
Durability of operational reliability, electrical stability	passed	5.14

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. Signed for and on behalf of the manufacturer by:



Motti Barad, Certification Engineer

22 October 2013  
Rishon LeZion, Israel