



DECLARATION OF PERFORMANCE

1. Unique identification code of the product-type: **DOP_ EL-5803 (1134-CPR-219)**
2. Intended use/es: **Smoke Alarms installed in buildings**
3. Manufacturer: **RISCO Ltd. , 14 Hachoma Street ,75655 Rishon LeZion, Israel**
4. Authorised representative:**N/A**
5. System/s of AVCP:**N/A**
6.
 - (a) Harmonised standard: **EN 14604:2005/AC:2008**

The Notified Product Certification Body, 1134 (ANPI Certification)

- (b) European Assessment Document:**N/A**

7. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	4.12, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18
Operational reliability	Pass	4.1, 4.2, 4.5, 4.6, 4.7, 4.9, 4.10, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22
Electrical Safety	Pass	5.24
Tolerance to supply voltage	Pass	5.21
Durability of operational reliability and response delay	Pass	5.7, 5.8
Durability of operational reliability,vibration resistance	Pass	5.12, 5.13
Durability of operational reliability,humidity resistance	Pass	5.9
Durability of operational reliability,corrosion resistance	Pass	5.10
Durability of operational reliability,electrical stability	Pass	5.14



UPGRADING
EVERYDAY
SECURITY

8. Appropriate Technical Documentation and/or Specific Technical Documentation:**N/A**

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

A handwritten signature in blue ink, appearing to be 'Motti Barad', written over a faint horizontal line.

Motti Barad, Certification Engineer

13 February 2019
Rishon LeZion, Israel